Town of Londonderry Request for Proposals Emergency Generator Installation Twitchell Building (EOC)

The Town of Londonderry is seeking proposals for a generator project at the Twitchell Building (EOC) – Town Office Building.

Proposals should be submitted to:

Town of Londonderry

EOC Generator Bids 100 Old School Street

South Londonderry, VT 05155

Proposals will be accepted until Friday November 4, 2016. For additional information or questions on the specifications of the project, please contact Stephanie Thompson at townadmin@londonderryvt.org or at (802) 824-3356.

Qualifications:

Proposals will only be accepted from submitters with a demonstrated history relative to the project.

Bid Specifications:

- Installation of Generator - Minimum 50 KW diesel or propane generator with at least 200 amp ATS and a weather-

- Installation of a concrete slab with dimensions of 10' x 6'.

- proof, secure/locking enclosure.
 Installation and connection to existing building electric
- systems.
 Necessary trenching, feed line, conduit and pavement repair.

Additional Guidelines

- Contractor will reconnect all systems related to the project.Bidders shall clearly specify payment terms for their
- proposals.
 Bidders shall clearly identify costs associated with
- Bidders shall clearly identify costs associated with equipment/parts and labor separately.

Contract Awards

- The Town of Londonderry reserves the right to reject any and all bids which may be submitted. It also reserves the right to award a contract(s) to the bidder who, in the opinion of the Town, will best meet the needs of the Town and the project.